



NOTE

*Depth to bottom of footing for new homes shall be a minimum of 60".
Drop footings may be required.*

Where 60" depth to bottom of footing cannot be achieved due to existing conditions, frost protection must be accomplished using 2" rigid foam insulation under the gravel bed extending horizontally from the foundation wall to the outer wall of the window well.