

ADDENDUM #2

City of Duluth
Maintenance Shop Slab Replacement
Project #: 10-08B
Bid #: 10-0437

The following addendum shall become part of the construction documents for the construction of the above referenced project. This addendum supersedes and supplements all previous reference to similar items.

CITY OF DULUTH PROJECT REQUIREMENTS

Add the following:

Reference drawing E3-Electrical Schedules and Risers:

See Details 2/E3 and 3/E3: Add 100A Panel H, located in Signal Shop.

Provide Type F feeder to new junction box for Panel H. Apply Keyed Note #2 to panel H.

Reference panel schedule for Panel MSP:

Add 100/2 circuit breaker to circuit 28, 30 to feed Panel H.

END OF ADDENDUM #2