

ADDENDUM

THE FOLLOWING ATTACHED
HERETO:
Pre-Bid Attendance List

ADDENDUM NO. 2

ARCHITECT:
City of Duluth
Tari Rayala

PROJECT:
Duluth City Hall Generator
Replacement
G&M Project No. 83295

OWNER:
City of Duluth
Joe Miller

DATE:
September 11, 2014

Sent from:

St. Paul Office
700 Rosedale Tower
1700 Highway 36 West
St. Paul, MN 55113
Phone: 651-639-9606
FAX: 651-639-9618

Duluth Office
Suite 310
501 South Lake Avenue
Duluth, MN 55802
Phone: 218-722-2555
FAX: 218-722-9306

Santa Clarita Office
Suite 205
26415 Carl Boyer Drive
Santa Clarita, CA 91350
Phone: 661-291-1978
FAX: 661-291-6213

To: Prime Contract Bidders and all others to whom the Project Manual and the Project Drawings have been issued by the Architect/Engineer or Contractor.

This Addendum is a Contract Document and may apply to any or all Contracts and subcontracts. Unless otherwise specified herein or shown on the attached drawings (if any), all work required by this Addendum shall be in complete accord with the Contract Documents and subsequent Addenda thereto.

The items listed in this Addendum are not in any order in regard to the Project Drawings or the Project Manual. All contractors are cautioned to examine each and every item of this Addendum.

The bidder shall insert the Addendum number in the space indicated on the Project Proposal Form. Failure to comply may result in the bid being rejected.

<u>ITEM</u>	<u>CHANGE/COMMENTS</u>
1.	Refer to attached attendance list associated with mandatory pre-bid walk-thru requirements issue via addendum #1.
2.	Sealed bid due date as published in the City of Duluth Invitation to Bid and modified via addendum #1 to 9/16/14 has been extended to Tuesday, September 23, 2014. All other requirements stated in project manual remain unless noted otherwise.
3.	Specified completion schedule of 120 days from Notice to Proceed remains in effect. However, schedule adjustments will be considered as stated in project manual. This includes but is not limited to major equipment deliveries/ delays such as generator package.
4.	Existing and new natural gas piping system requirements are stated on sheets M1.0 and M1.1 included in project.

5. Any utility changes associated with the specified gas meter replacement will be directed to City of Duluth. This does not relieve this contractor from coordination and final connection requirements.
6. General Conditions, Part 1, Item 107; For clarification purposes, development of progress schedule shall be based on normal working hours Monday through Friday. Completion of work tasks outside of normal working hours is not required. Progress schedule shall also include detailed work plan associated with electrical service interruptions during equipment replacement/ installation for approval by owner.
7. General Conditions, Part 1, Item 111.b; For clarification purposes "Section 7 (Specific Conditions)" was not issued and therefore liquidated damages are not included. This does not relieve the contractor for obligations under Part 1, Item 119.
8. Specification Section 263213; Part 2.2.A: Add as follows: "EPA Certified".
9. Sheet M2.0 Numbered Note 3; Replace with the following: "Exhaust Flue Wall Thimble furnished by Div. 26 contractor and installed by Div. 23 contractor".
10. Sheet M2.0 Numbered Note 8; Replace with the following: "Exhaust Flue Flex Connection furnished by Div. 26 contractor and installed by Div. 23 contractor".

Project City of Duluth Genset Replacement Project No. _____
 Subject Attend List
 Date 9/9/14 Page 1 of _____

<u>Name</u>	<u>Company</u>	<u>Contact info</u>
Scott Haedtke	Gausman & Moore	SHAEDTKE@GAUSMAN.COM
Luke Thibault	INDEPENDENCE HTB.	Luke (218) 520-3063
CHRIS KROOK	Belknap Electric, Inc.	CHRISKROOK@BELKNAPLECTRIC.COM
Doug Abramson (651-402-7183)	Cummins NPower LLC	douglas.p.abramson@cummins.com
Steve Becks	NYLUND Electric	SSBecks@nylundelectric.com
Steve Siso	CENTRAL STREET META	steve@csmsuperior.com
Dave Muralski	Electric Systems	CONTACT@ELECTRICSYSTEMSOFDULUTH.COM
Denny Johnson	PARSONS ELECTRIC	DENNY.JOHNSON@PARSONSCORP.COM
Rick Johnson	Hunt Electric	rjohnson@huntelec.com
WAREY ABRAMSON	CITY OF DULUTH	LABRAMSON@DULUTHMN.GOV